

# Drinking Water Watch

## Disinfection By-Products Sample Report

<b>Water System:</b>	OH7400411	FOSTORIA CITY	<b>Sample Collected:</b>	07/05/2023	12.30 PM
<b>Facility Source/Plant :</b>	DS1	FOSTORIA CITY DISTRIBUTION	<b>Lab Received:</b>	07/11/2023	
<b>Sampling Pt:</b>	DS201	1203 PEELER DR.			
<b>Address:</b>	1203 PEELER				
<b>Sample Type:</b>	ROUTINE	<b>For Compliance:</b>	Yes		
<b>Lab Sample No:</b>	2324288-01	<b>Laboratory:</b>	838	ALLOWAY MARION LABORATORY	
<b>State Sample No:</b>	null				

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2950	TTHM	524.2	07/20/2023	07/20/2023	
<b>Detection:</b>	51.7 UG/L				

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2944	DIBROMOCHLOROM	524.2	07/20/2023	07/20/2023	
<b>Detection:</b>	3.3 UG/L				

Water System: OH7400411  
Facility Source/Plant : DS1  
Sampling Pt: DS201  
Address: 1203 PEELER  
Sample Type: ROUTINE  
Lab Sample No: 2324288-01  
State Sample No:

FOSTORIA CITY  
FOSTORIA CITY DISTRIBUTION  
1203 PEELER DR.

Sample Collected: 07/05/2023 12.30 PM  
Lab Received: 07/11/2023

For Compliance: Yes  
Laboratory: 838

ALLOWAY MARION LABORATORY

null

---

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2943	BROMODICHLOROM	524.2	07/20/2023	07/20/2023	
Detection:	8.6 UG/L				

---

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2942	BROMOFORM	524.2	07/20/2023	07/20/2023	
Detection:	0.6 UG/L				

---

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2941	CHLOROFORM	524.2	07/20/2023	07/20/2023	
Detection:	39.2 UG/L				

---

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2456	TOTAL HALOACETIC	552.2	07/20/2023	07/20/2023	
Detection:	15 UG/L				

**Water System:** OH7400411 FOSTORIA CITY  
**Facility Source/Plant :** DS1 FOSTORIA CITY DISTRIBUTION  
**Sampling Pt:** DS201 1203 PEELER DR.  
**Address:** 1203 PEELER  
**Sample Type:** ROUTINE **For Compliance:** Yes  
**Lab Sample No:** 2324288-01 **Laboratory:** 838  
**State Sample No:**

**Sample Collected:** 07/05/2023 12.30 PM  
**Lab Received:** 07/11/2023

ALLOWAY MARION LABORATORY

null

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2454	DIBROMOACETIC	552.2	07/20/2023	07/20/2023	
<b>Detection:</b> < 1 UG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2453	MONOBROMOACETI	552.2	07/20/2023	07/20/2023	
<b>Detection:</b> < 1 UG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2452	TRICHLOROACETIC	552.2	07/20/2023	07/20/2023	
<b>Detection:</b> 4.9 UG/L					

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2451	DICHLOROACETIC	552.2	07/20/2023	07/20/2023	
<b>Detection:</b> 7.7 UG/L					

Water System: OH7400411  
Facility Source/Plant : DS1  
Sampling Pt: DS201  
Address: 1203 PEELER  
Sample Type: ROUTINE  
Lab Sample No: 2324288-01  
State Sample No:

FOSTORIA CITY  
FOSTORIA CITY DISTRIBUTION  
1203 PEELER DR.

Sample Collected: 07/05/2023 12.30 PM  
Lab Received: 07/11/2023

For Compliance: Yes  
Laboratory: 838

ALLOWAY MARION LABORATORY

null

---

RESULT	Analyte	Method	Analysis Start and End Dates	State Notified On	PWS Notified On
2450	MONOCHLOROACE	552.2	07/20/2023	07/20/2023	
Detection:	2.4 UG/L				

---